



Product Description

The DIBt building rules list requires a verification of applicability for fire protection closures (a German approval from the building inspectorate or a European technical approval). These approvals stipulate a locking device when the systems are to be kept open in operation. The locking device must be suitable. Its applicability must be verified by means of an approval from the building inspectorate.

construction type	control units	Type of protection:	IP 65
proof	Z-6.5-1990 for conveyor system closure		
Fire alarm analysis	Pushbutton • Potential-free contact of central fire alarm system • Via fire alarm loop or smoke switch		
