



## RZ3/4

VdS tested and approved by the building authority

## Product Description

The DIBt building rules list requires a verification of applicability for fire protection closures (a German approval from the building inspectorate or a European technical approval). These approvals stipulate a locking device when the systems are to be kept open in operation. The locking device must be suitable. Its applicability must be verified by means of an approval from the building inspectorate.

---

**construction type**

control units

**Type of protection:**

IP 65

**proof**

Z-6.5-1484

**Fire alarm analysis**

Pushbutton • Via fire alarm loop or smoke switch • Potential-free contact of central fire alarm system

---