

## RZ3/4

Hold-open system VdS tested and approved by the building authority

## Product description

The DIBt building rules list requires proof of applicability for fire protection closures (a German technical approval from the building authority or a European technical approval). These approvals stipulate a hold-open system to keep the systems open during operation. The hold-open system must be suited for this task. Its applicability must be verified by means of a technical approval.

---

<b>Type</b>	Control unit	<b>Fire alarm analysis</b>	Push-button • Via fire alarm loop or smoke switch • Potential-free contact of fire alarm centre
<b>Proof of usability</b>	UL 864		
<b>Verification</b>	Z-6.5-1484	<b>Degree of protection</b>	IP 65

---