

## RZ8-FA

Hold-open system (Z-6.510-2428)

### Product description

Type for the installation of the hold-open system according to general type certification no. Z-6.500-2436 - as per data sheet

---

<b>Product designation</b>	Power supply with trigger device	<b>Operation / display</b>	Membrane keypad
<b>Rated voltage</b>	85...265V AC	<b>Casing (type)</b>	Spelsberg (ABS)
<b>Connected load</b>	65VA	<b>Casing (size)</b>	122x122x55 mm
<b>Control voltage</b>	24V DC	<b>Casing (colour)</b>	similar to RAL 7038
<b>Mains frequency</b>	47...63Hz	<b>Degree of protection</b>	IP 65
<b>Starting current</b>	10A	<b>Ambient temperature</b>	-10°...+40°C
<b>Output current</b>	900mA DC		

---

#### Note

The device combination RZ8 has to be installed in the detection range of the fire detectors of the respective closure; if necessary, an additional fire detector must be installed.